



## **Declaration of Conformity**

For the following equipmen	t:		
Product Name: Switching P	ower Supply		
Model Designation: RCP-M	U		
is herewith confirmed to coapplied:	omply with the requirements set or	ut in the Council Direc	ctive, the following standards were
RoHS Directive (2011)	(65/EU)		
Low Voltage Directive (2	2014/35/EU):		
EN60950-1:2006+A11:2009	9+A1:2010+A12:2011+A2:2013	LVD certifica	te No: 1401002001
Electromagnetic Comp	atibility Directive (2014/30/EL	J) :	
EMI (Electro-Magnetic Int Conducted emission / Radi			Class B
Harmonic current	EN61000-3-2:2014		
Voltage flicker	EN61000-3-3:2013		
EMS (Electro-Magnetic Su	usceptibility)		
EN55024:2010+A1:2015			
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008+A	2:2010 Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2014	Level 4	2KV/Line-Line
Surge susceptibility	EN61000-4-5:2014	Level 4	4KV/Line-Earth
Conducted susceptibility	EN61000-4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 4	30A/m
Voltage dip, interruption	EN61000-4-11:2004 >95% dip 0.5 p	periods 30% dip 25 perio	ds >95% interruptions 250 periods
be affected by the complete in again.		turers must re-qualify EM	equipment. Since EMC performance will C Directive on the complete installation on File).
This Declaration is effective from	m serial number RB7xxxxxxx		
Person responsible for mar	king this declaration:		
MEAN WELL Enterprises C (Manufacturer Name) No.28, Wuquan 3rd Rd., W	co., Ltd. ugu Dist., New Taipei City 248, Tai	wan	
(Manufacturer Address)	Λ		(0)
Johnny Huang/Manager, Certification Center:  (Name / Position)  Alex Tsai/Director, Marketing Department:  (Signature)  (Signature)			
Taiwan	Mar. 5th, 2017		

(Date)

(Place)